

RFP No. FY2024-01

Request for Proposals

Advanced Metering Infrastructure/Smart Utility Solution – Water & Sewer

ADDENDUM NO. 1

- 1.0** Delete the word “flow” on p18 of Request for Proposal under Gravity Sewers 1.0 Sentence should read” **Install Smart Covers utilizing ultrasonic sensors to monitor the level.**
- 2.0** Add 3.0 in Gravity Sewers section on p18 of Request for Proposals to read **3.0 Provide a sewer flow monitoring system.**